



PERFORMANCE CERTIFICATE OF COMPLIANCE (Part 1 of 3) PERF-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Climate Zone: CA Climate Zone 12
Total Cond. Floor Area: 7,087
Addition Floor Area: n/a
GENERAL INFORMATION: Building Type: Nonresidential, Relocatable Public School Bldg.
STATEMENT OF COMPLIANCE: This certificate of compliance lists the building features and specifications needed to comply with Title 24, Parts 1 and 6 of the California Code of Regulations.
Documentation Author: Mangabe Suresh
Principal Envelope Designer: B.R. Gounda Rao P.E.
Principal Mechanical Designer: Ajmani & Pamidi Inc.
Principal Lighting Designer: Satish Pamidi P.E.

PERFORMANCE CERTIFICATE OF COMPLIANCE (Part 2 of 3) PERF-1C
ANNUAL TDV ENERGY USE SUMMARY (kBtu/sqft-yr)
Energy Component: Space Heating, Space Cooling, Indoor Fans, Heat Rejection, Pumps & Misc., Domestic Hot Water, Lighting, Receptacle, Process, Process Lighting.
BUILDING COMPLIES
GENERAL INFORMATION: Building Orientation: (E) 90 deg, Number of Stories: 1, Number of Systems: 9, Number of Zones: 15.
Prescriptive Lighting Power Density: 1.054 W/sqft, Proposed: 0.799 W/sqft.
Prescriptive Envelope TDV Energy: 198.510 W/sqft, Proposed: 146.329 W/sqft.


PERFORMANCE CERTIFICATE OF COMPLIANCE (Part 3 of 3) PERF-1C
ZONE INFORMATION
System Name, Zone Name, Occupancy Type, Floor Area (sqft), Inst. LPD (W/sqft), Cnt. Credits (W/sqft), Allowed LPD Area (W/sqft), Tailored (W/sqft), Proc. Loads (W/sqft).
EXCEPTIONAL CONDITIONS COMPLIANCE CHECKLIST
The local enforcement agency should pay special attention to the items specified in this checklist. These items require special written justification and documentation, and special verification to be used with the performance approach.

PERFORMANCE CERTIFICATE OF COMPLIANCE (Part 3 of 3) PERF-1C
ZONE INFORMATION
System Name, Zone Name, Occupancy Type, Floor Area (sqft), Inst. LPD (W/sqft), Cnt. Credits (W/sqft), Allowed LPD Area (W/sqft), Tailored (W/sqft), Proc. Loads (W/sqft).
EXCEPTIONAL CONDITIONS COMPLIANCE CHECKLIST
The local enforcement agency should pay special attention to the items specified in this checklist. These items require special written justification and documentation, and special verification to be used with the performance approach.

REVISIONS BY
ISSUE FOR PERMIT 10-28-11

IYER & ASSOCIATES
Architecture Interiors Planning
1100 Montgomery Street
SAN FRANCISCO, CA 94133
415 362-4837 (OFF)
FAX 415 362-8158
2011@IYER & ASSOCIATES

Ajmani & Pamidi Inc.
Mechanical & Electrical Engineers
101 California St., Suite 2025
San Francisco, California 94111
Ph (415) 543-9344 Fax (415) 543-9670
E-mail: Main@Ajmani.com 09/21/10



TITLE-24 COMPLIANCE FORMS
BUILDING "D"
HINDU COMMUNITY and CULTURAL CENTER
1200 ARROWHEAD AVE. LIVERMORE, CA 94551


CERTIFICATE OF COMPLIANCE AND FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 3) ENV-1C
FIELD INSPECTION ENERGY CHECKLIST
OPAQUE SURFACE DETAILS: TagID, Assembly Type, Area (ft^2), Orientation, U-Factor, etc.
FENESTRATION SURFACE DETAILS: TagID, Fenestration Type, Area (ft^2), Orientation, U-Factor, etc.

CERTIFICATE OF COMPLIANCE AND FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 3) ENV-1C
FIELD INSPECTION ENERGY CHECKLIST
OPAQUE SURFACE DETAILS: TagID, Assembly Type, Area (ft^2), Orientation, U-Factor, etc.
FENESTRATION SURFACE DETAILS: TagID, Fenestration Type, Area (ft^2), Orientation, U-Factor, etc.

CERTIFICATE OF COMPLIANCE AND FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 3) ENV-1C
FIELD INSPECTION ENERGY CHECKLIST
OPAQUE SURFACE DETAILS: TagID, Assembly Type, Area (ft^2), Orientation, U-Factor, etc.
FENESTRATION SURFACE DETAILS: TagID, Fenestration Type, Area (ft^2), Orientation, U-Factor, etc.

CERTIFICATE OF COMPLIANCE AND FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 3) ENV-1C
FIELD INSPECTION ENERGY CHECKLIST
OPAQUE SURFACE DETAILS: TagID, Assembly Type, Area (ft^2), Orientation, U-Factor, etc.
FENESTRATION SURFACE DETAILS: TagID, Fenestration Type, Area (ft^2), Orientation, U-Factor, etc.

DATE: 10/28/11
SCALE: NONE
DRAWN BY: PT
PROJECT: ARROWHEAD



T-24.1



CERTIFICATE OF COMPLIANCE (Part 3 of 3) LTG-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Indoor Lighting Power for Conditioned Spaces vs. Unconditioned Spaces table with columns for Watts, Installed Lighting, and Lighting Control Credit.
Required Acceptance Tests Designer section.
Luminaires Controlled table with columns for Equipment Requiring Testing, Description, Location, and Controls and Sensors and Automatic Dimming Controls Acceptance.

LIGHTING CONTROLS CREDIT WORKSHEET (Part 1 of 2) LTG-2C
Project Name: HCC Bldg. D
Date: 10/27/2011
POWER ADJUSTMENT FACTORS (PAF) FOR NON-DAYLIGHT CONTROLS
A Separate PAF Worksheet Must Be Filled Out for Conditioned and Unconditioned Spaces. Control Credits listed on this schedule are only for:
Table with columns A, B, C, D, E, F, G for Room # Zone ID, Lighting Description, Plan Reference, Room Area, Watts of Control Lighting, Power Adjustment Factor, and Control Credit.
Total: 131

CERTIFICATE OF COMPLIANCE and FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 4) MECH-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Climate Zone: 12, Total Cond. Floor Area: 7,087, Addition Floor Area: n/a
GENERAL INFORMATION
HVAC SYSTEM DETAILS table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).
FIELD INSPECTION ENERGY CHECKLIST table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).

CERTIFICATE OF COMPLIANCE and FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 4) MECH-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Climate Zone: 12, Total Cond. Floor Area: 7,087, Addition Floor Area: n/a
GENERAL INFORMATION
HVAC SYSTEM DETAILS table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).
FIELD INSPECTION ENERGY CHECKLIST table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).

CERTIFICATE OF COMPLIANCE and FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 4) MECH-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Climate Zone: 12, Total Cond. Floor Area: 7,087, Addition Floor Area: n/a
GENERAL INFORMATION
HVAC SYSTEM DETAILS table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).
FIELD INSPECTION ENERGY CHECKLIST table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).


CERTIFICATE OF COMPLIANCE and FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 4) MECH-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Climate Zone: 12, Total Cond. Floor Area: 7,087, Addition Floor Area: n/a
GENERAL INFORMATION
HVAC SYSTEM DETAILS table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).
FIELD INSPECTION ENERGY CHECKLIST table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).

CERTIFICATE OF COMPLIANCE and FIELD INSPECTION ENERGY CHECKLIST (Part 1 of 4) MECH-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Climate Zone: 12, Total Cond. Floor Area: 7,087, Addition Floor Area: n/a
GENERAL INFORMATION
HVAC SYSTEM DETAILS table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).
FIELD INSPECTION ENERGY CHECKLIST table with columns Equipment, Inspection Criteria, Meets Criteria or Requirements (Pass/Fail - Describe Reason).

CERTIFICATE OF COMPLIANCE and FIELD INSPECTION ENERGY CHECKLIST (Part 2 of 4) MECH-1C
Project Name: HCC Bldg. D
Date: 10/27/2011
Discrepancies table for listing any differences between proposed and actual equipment performance.

REVISIONS BY table with columns for Issue No., Description, and Date.

IYER & ASSOCIATES
Architectural Interiors Planning
1100 Montgomery Street
SAN FRANCISCO, CA 94133
415 362-4837 (OFF)
FAX 415 362-8158



Ajmani & Pamidi Inc.
Mechanical & Electrical Engineers
101 California St., Suite 2025
San Francisco, California 94111
Ph (415) 543-9344 Fax (415) 543-9670
E-mail: Mail@AjmaniPamidi.com (92012D)

TITLE-24 COMPLIANCE FORMS
BUILDING "D"
HINDU COMMUNITY and CULTURAL CENTER
1200 ARROWHEAD AVE. LIVERMORE, CA 94551

DATE: 10/28/11
SCALE: NONE
DRAWN BY: PT
PROJECT: ARROWHEAD

T-24.3





**MECHANICAL EQUIPMENT DETAILS** (Part 1 of 2) **MECH-5C**  
 Project Name: HCC Bldg. D Date: 10/27/2011

**CHILLER AND TOWER SUMMARY**

Equipment Name	Type	Qty	Efficiency	Tons	Qty	CFM	BHP	Pump Control

**DHW / BOILER SUMMARY**

System Name	Type	Distribution	Qty	Rated Input	Vol. (Gals)	Energy Factor or EER	Standby Loss or P/B	Tank Ext. (Gals)	Status
Room # RC8BPH-NG	Instant Gas	Kitchen Pipe Hot	1	190,000	0	0.85			

**MULTIFAMILY CENTRAL WATER HEATING DETAILS**

Control	No. Water Pump	Type	In Plenum	Hot Water Piping Length (ft)	Outside	Inside	Add 1/2" Insulation

**CENTRAL SYSTEM RATINGS**

System Name	Type	Qty	HEATING		COOLING		Status	
			Output	Efficiency	Output	Efficiency		
Trans YHC-060	Packaged DX	3	48,900	0.0	83% AFUE	62,400	12.0 SEER / 12.7 EER	

**CENTRAL SYSTEM FAN SUMMARY**

System Name	Fan Type	Economizer Type	SUPPLY FAN		RETURN FAN	
			CFM	BHP	CFM	BHP
Trans YHC-060	Constant Volume	No Economizer	2,000	1.60		

EnergyPro 5.1 by EnergySoft User Number: 2849 RunCode: 2011-10-27T11:45:56 ID: Bid\_D Page 35 of 59

**MECHANICAL EQUIPMENT DETAILS** (Part 2 of 2) **MECH-5C**  
 Project Name: HCC Bldg. D Date: 10/27/2011

**ZONE SYSTEM SUMMARY**

Zone Name	System Name	Type	Qty	Heating	Cooling	Min CFM Ratio	Reheat Coil	CFM	BHP	Fpn		Outside Air
Zone-1	CAV Box/No Reheat	VAV Box	1	0	0	100%	None					

**EXHAUST FAN SUMMARY**

Room Name	Qty	CFM	BHP	Room Name	Qty	CFM	BHP	Room Name	Qty	CFM	BHP

EnergyPro 5.1 by EnergySoft User Number: 2849 RunCode: 2011-10-27T11:45:56 ID: Bid\_D Page 36 of 59

**LIGHTING CONTROLS CREDIT WORKSHEET** (Part 1 of 2) **LTG-2C**  
 Project Name: HCC Bldg. D Date: 10/27/2011

**POWER ADJUSTMENT FACTORS (PAF) FOR NON-DAYLIGHT CONTROLS**  
 A Separate PAF Worksheet Must Be Filled Out for Conditioned and Unconditioned Spaces. Control Credits listed on this schedule are only for:

**CONDITIONED SPACES**  **UNCONDITIONED SPACES**

Room # Zone ID Area	Lighting Control Description <sup>1</sup>	Plan Reference	Room Area (ft <sup>2</sup> )	Watts of Control Lighting	Power Adjustments Factor <sup>2</sup>	Control Credit Watts (E x F)
Corridor # 2/Vestib	Occ Sensor - Hallway	L2	440	150	0.25	38
Corridor # 1	Occ Sensor - Hallway	L2	150	90	0.25	23
Storage Rm # 113	Occ Sensor - Storage	L7	56	60	0.15	9
Corridor # 108	Occ Sensor - Hallway	L2	520	210	0.25	53
Janitor Rm # 107	Occ Sensor - Storage	L7	30	60	0.15	9

Page Total: 131

Note: Conditioned and Unconditioned Space shall be separately totaled.

1. Description shall be consistent with Type of Control defined in Table 148-C  
 2. Power Adjustment Factor taken from Table 148-C

EnergyPro 5.1 by EnergySoft User Number: 2849 RunCode: 2011-10-27T11:45:56 ID: Bid\_D Page 28 of 59

**ENVELOPE MANDATORY MEASURES: NONRESIDENTIAL** **ENV-MM**  
 Project Name: HCC Bldg. D Date: 10/27/2011

**DESCRIPTION**

**Building Envelope Measures:**

§118(a): Installed insulating material shall have been certified by the manufacturer to comply with the California Quality Standards for insulating material, Title 20 Chapter 4, Article 3.

§118(c): All Insulating Materials shall be installed in accordance with the flame spread rating and smoke density requirements of Sections 2802 and 707 of Title 24, Part 2.

§118(f): The opaque portions of framed demising walls in nonresidential buildings shall have insulation with an installed R-value of no less than R-13 between framing members.

§117(a): All Exterior Joints and openings in the building that are observable sources of air leakage shall be caulked, gasketed, weatherstripped or otherwise sealed.

§116(a) 1: Manufactured fenestration products and exterior doors shall have air infiltration rates not exceeding 0.3 cfm/ft<sup>2</sup> of window area, 0.3 cfm/ft<sup>2</sup> of door area for residential doors, 0.3 cfm/ft<sup>2</sup> of door area for nonresidential single doors (swinging and sliding), and 1.0 cfm/ft<sup>2</sup> for nonresidential double doors (swinging).

§116(a) 2: Fenestration U-factor shall be rated in accordance with NFRC 100, or the applicable default U-factor.

§116(a) 3: Fenestration SHGC shall be rated in accordance with NFRC 200, or NFRC 100 for site-built fenestration, or the applicable default SHGC.

§116(b): Site Constructed Doors, Windows and Skylights shall be caulked between the unit and the building, and shall be weatherstripped (except for unframed glass doors and fire doors).

EnergyPro 5.1 by EnergySoft User Number: 2849 RunCode: 2011-10-27T11:45:56 ID: Bid\_D Page 37 of 59

**LIGHTING MANDATORY MEASURES: NONRESIDENTIAL** **LTG-MM**  
 Project Name: HCC Bldg. D Date: 10/27/2011

**Indoor Lighting Measures:**

§131(d): **Shut-off Controls**  
 For every floor, all interior lighting systems shall be equipped with a separate automatic control to shut off the lighting switch, or other device capable of automatically shutting off the lighting.

§119(h): **Override for Building Lighting Shut-off:** The automatic building shut-off system is provided with a manual, accessible override switch in sight of the lights. The area of override is not to exceed 5,000 square feet.

§111: **Automatic Control Devices Certified:** All automatic control devices specified are certified, all alternate equipment shall be certified and installed as directed by the manufacturer.

§111: **Fluorescent Ballast and Luminaires Certified:** All fluorescent fixtures specified for the project are certified and listed in the Directory. All installed fixtures shall be certified.

§131(a): **Individual Room/Area Controls:** Each room and area in this building is equipped with a separate switch or occupancy sensor device for each area with foot-to-ceiling walls.

§131(b): **Uniform Reduction for Individual Rooms:** All rooms and areas greater than 100 square feet and more than 0.8 watts per square foot of lighting load shall be controlled with bi-level switching for uniform reduction of lighting within the room.

§131(c): **Daylight Area Control:** All rooms with windows and skylights that are greater than 250 square feet and that allow for the effective use of daylight in the area shall have 50% of the lamps in each daylight area controlled by a separate switch, or the effective use of daylight cannot be accomplished because the windows are continuously shaded by a building or the adjacent lot. Diagram of shading during different times of the year is included on plans.

§131(c): **Display Lighting:** Display lighting shall be separately switched on circuits that are 20 amps or less.

**Outdoor Lighting Measures:**

§130(c) 1: Mandatory lighting power determination for medium base sockets without permanently installed ballasts.

§132(a): All permanently installed luminaires with lamps rated over 100 Watts either have a lamp efficacy of at least 60 lumens per Watt or are controlled by a motion sensor.

§132(b): All luminaires with lamps rated greater than 175 Watts in hardscape area, including parking lots, building entrances, canopies, and all outdoor sales areas meet the Cutoff Requirements.

§132(c): All permanently installed outdoor lighting meets the control requirements listed.

§132(c): Building facades, parking lots, garages, canopies, and outdoor sales areas meet the Multi-Level Lighting Requirements listed.

EnergyPro 5.1 by EnergySoft User Number: 2849 RunCode: 2011-10-27T11:45:56 ID: Bid\_D Page 38 of 59

**MECHANICAL MANDATORY MEASURES: NONRESIDENTIAL** **MECH-MM**  
 Project Name: HCC Bldg. D Date: 10/27/2011

**Equipment and System Efficiencies**

§111: Any appliance for which there is a California standard established in the Appliance Efficiency Regulations will comply with the applicable standard.

§115(a): Fan type central furnaces shall not have a pilot light.

§123: Piping, except that conveying fluids at temperatures between 60 and 105 degrees Fahrenheit, or within HVAC equipment, shall be insulated in accordance with Standards Section 123.

§124: Air handling duct systems shall be installed and insulated in compliance with Sections 601, 602, 603, 604, and 605 of the CMC Standards.

**Controls**

§122(a): Each space conditioning system shall be installed with one of the following:  
 1A. Each space conditioning system serving building types such as offices and manufacturing facilities (and all others not explicitly exempt from the requirements of Section 112 (d)) shall be installed with an automatic time switch with an accessible manual override that allows operation of the system during off-hours for up to 4 hours. The time switch shall be capable of programming different schedules for weekdays and weekends and have program backup capabilities that prevent the loss of the device's program and time setting for at least 10 hours if power is interrupted, or  
 1B. An occupancy sensor to control the operating period of the system, or  
 1C. A 4-hour timer that can be manually operated to control the operating period of the system.

§122(a): Each space conditioning system shall be installed with controls that temporarily restart and temporarily operate the system as required to maintain a setback heating and/or a setup cooling thermostat setpoint.

§122(b): Each space conditioning system serving multiple zones with a combined conditioned floor area more than 25,000 square feet shall be provided with isolation zones. Each zone shall not exceed 25,000 square feet; shall be provided with isolation devices, such as valves or dampers that allow the supply of heating or cooling to be setback or shut off independently of other isolation areas; and shall be controlled by a time control device as described above.

§122(c): Thermostats shall have numeric setpoints in degrees Fahrenheit (F) and adjustable setpoint stops accessible only to authorized personnel.

§122(d): Heat pumps shall be installed with controls to prevent electric resistance supplementary heater operation when the heating load can be met by the heat pump alone.

§122(a&b): Each space conditioning system shall be controlled by an individual thermostat that responds to temperature within the zone. Where used to control heating, the control shall be adjustable down to 55 degrees F or lower. For cooling, the control shall be adjustable up to 85 degrees F or higher. Where used for both heating and cooling, the control shall be capable of providing a deadband of at least 5 degrees F within which the supply of heating and cooling is shut off or reduced to a minimum.

**Ventilation**

§121(e): Controls shall be provided to allow outside air dampers or devices to be operated at the ventilation rates as specified on these plans.

§122(f): All gravity ventilating systems shall be provided with automatic or readily accessible manually operated dampers in all openings to the outside, except for combustion air openings.

§121(f): Ventilation System Acceptance. Before an occupancy permit is granted for a newly constructed building or space, or a new ventilating system serving a building or space is operated for normal use, all ventilation systems serving the building or space shall be certified as meeting the Acceptance Requirements for Code Compliance.

**Service Water Heating Systems**

§113(c): Installation  
 3. Temperature controls for public lavatories. The controls shall limit the outlet Temperature to 110° F.  
 2. Circulating service water heating systems shall have a control capable of automatically turning off the circulating pump when hot water is not required.


EnergyPro 5.1 by EnergySoft User Number: 2849 RunCode: 2011-10-27T11:45:56 ID: Bid\_D Page 39 of 59

REVISIONS	BY
ISSUE FOR PERMIT 10-28-11	

**IYER & ASSOCIATES**  
 Architecture Interiors Planning  
 1100 Montgomery Street  
 SAN FRANCISCO, CA 94133  
 415 362-4837 (OFF)  
 415 362-8158  
 2011 © IYER & ASSOCIATES



**Ajmani & Pamidi Inc.**  
 Mechanical & Electrical Engineers  
 101 California St., Suite 2025  
 San Francisco, California 94111  
 Ph (415) 543-9344 Fax (415) 543-0670  
 E-mail: Main@AjPincSF.com 09021(D)



TITLE-24 COMPLIANCE FORMS  
**BUILDING "D"**  
**HINDU COMMUNITY and CULTURAL CENTER**  
 1200 ARROWHEAD AVE. LIVERMORE, CA 94551

DATE: 10/28/11  
 SCALE: NONE  
 DRAWN BY: PT  
 PROJECT: ARROWHEAD

T-24.5

